Energy performance certificate (EPC)

168 Dykes Hall Road SHEFFIELD S6 4GQ	Energy rating **C**	Valid until: **19 November 2032** Certificate number: **6891-3419-3861-7121-0468**

Property type	Retail/Financial and Professional Services
Total floor area	29 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	5 | A
If typical of the existing stock	22 | A

Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	39.93
Primary energy use (kWh/m2 per year)	415

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/1637-9358-5429-5008-2327).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	John Furniss
Telephone	0114 268 6533
Email	john.furniss@uwclub.net

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/015292
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

Assessment details

Employer	Furniss Property Instructions Ltd
Employer address	52, High Storrs Drive, Sheffield, S11 7LL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	15 November 2022
Date of certificate	20 November 2022